

Business Unit: ERA Technology Limited

Report Title: **Proof and Voltage Breakdown Test to IEC 61111 on Floor Mat**

Author: Peter Shepherd

Client: LS Cable Ltd

Report Number: 2011-0115 Issue 2

Project Number: 7M0661001

Report Version: Final Report

Document Control: Commercial-in-Confidence

Report Checked by:



Barry Knox
Principal Engineer

Approved by:



Dr Alan Friday
Head of Materials & Design

March 2011

Ref. K:\Projects (7 series)\7M - Materials Design & Consultancy\7M0661001 LS Cable Ltd (12062)\Reporting\7M0661001.doc

PURPOSE OF DISTRIBUTION:

This document is distributed to LS Cable Ltd for the sole purpose of commercial and technical use. Rights to copy or distribute this document are only granted for the stated purpose. The document may not otherwise be used or distributed without the prior written permission of ERA Technology Limited.

- © ERA Technology Limited 2011
All Rights Reserved
No part of this document may be copied or otherwise reproduced without the prior written permission of ERA Technology Limited. If received electronically, recipient is permitted to make such copies as are necessary to: view the document on a computer system; comply with a reasonable corporate computer data protection and back-up policy and produce one paper copy for personal use.

Distribution List

Client	(1)
Project File	(1)
Information Centre	(1)

DOCUMENT CONTROL

Distribution of this document by the recipient(s) is authorised in accordance with the following commercial restrictive markings:

Commercial-in-confidence : No distribution or disclosure outside of the recipient's organisation is permitted without the prior written permission of ERA Technology Limited.

Distributed-in-confidence : Distribution of the document shall be in accordance with the document distribution list and no further distribution or disclosure shall be allowed without the prior written permission of ERA Technology Limited.

Recipient-in-confidence : ERA Technology Limited distributes this document to the recipient on the condition that no further distribution or disclosure by the recipient shall be allowed.

Where specified the document may only be used in accordance with the 'Purpose of Distribution' notice displayed on the cover page.

For the purpose of these conditions, the recipient's organisation shall not include parent or subsidiary organisations.

Permission to disclose within recipient's organisation does not extend to allowing access to the document via Internet, Intranet or other web-based computer systems.

Commercial restrictive markings are as contained in page header blocks.

If no restrictive markings are shown, the document may be distributed freely in whole, without alteration, subject to Copyright.

ERA Technology Limited
Cleeve Road
Leatherhead
Surrey KT22 7SA, England
Tel : +44 (0) 1372 367350
Fax: +44 (0) 1372 367359

Read more about ERA Technology Limited on our Internet page at: www.era.co.uk

Client: LS Cable Ltd

Test Method: Proof and voltage breakdown tests to IEC 61111 clauses 5.6.4.2 and 5.5.4.3

Equipment Used: ERA 100 kV test rig no.76-023, calibration due 06/06/11

Preconditioning: 24 Hours at 90 ± 2 °C and RH $40 \pm 5\%$

Surrounding medium: Clean Diala B oil

Material: LS Rubber Floorcovering (Safe-Marine)

Date of test: 2nd March 2011

Results:

Sample	Proof test 1	Proof test 2	Proof test 3	Proof test 4	Proof test 5	Breakdown Voltage
1	5 kV 3 min	10 kV 3 min	20 kV 3 min	30 kV 3 min	40 kV 3 min	63 kV
2	5 kV 3 min	10 kV 3 min	20 kV 3 min	30 kV 3 min	40 kV 3 min	58 kV
3	5 kV 3 min	10 kV 3 min	20 kV 3 min	30 kV 3 min	40 kV 3 min	62 kV
4	5 kV 3 min	10 kV 3 min	20 kV 3 min	30 kV 3 min	40 kV 3 min	61 kV
5	5 kV 3 min	10 kV 3 min	20 kV 3 min	30 kV 3 min	40 kV 3 min	59 kV

Conclusion:

IEC 61111 Table 4 details the proof voltage and breakdown voltages required for various classes of electrical matting from 0 through to 4.

Class 1 requires a 3 minute proof test at 10 kV and a breakdown voltage of ≥ 20 kV. Class 2 requires a 3 minute proof test at 20kV and breakdown voltage of ≥ 30 kV. Class 3 requires a 3 minute proof test at 30 kV and a breakdown voltage of ≥ 40 kV. Class 4 requires a 3 minute proof test at 40 kV and a breakdown voltage of ≥ 50 kV. The samples of LS Rubber Floorcovering (Safe-Marine) tested therefore meet class 4 of IEC 61111.